

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0078:184 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: ADEMCO, 165 Eileen Way, Syosset, NY 11791
Contact: Dave Kalmus (516) 921-6704

DESIGN: Model HN1224 horn. Models HN1224 is not suitable for public mode fire alarm service when used at low volume on 12V control panels. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 10.5 - 30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as audible devices for use with separately listed compatible fire alarm control units. For indoor use only. Model HN1224 can generate the Temporal Pattern signal in accordance with NFPA 72, 1993 Edition.

XLF: 7135-1209:143

04-23-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager